


-14-06



Those blocks upon which the supporting steel channels are mounted shall be smooth faced on the mounting side

attached with 3-7
studs, see DETAIL

When sound wall as measured from the bottom of the gate opening exceeds 6'-8" or 7'-0", see 5'-0" GATE DETAILS (2) sheet.

All wood to be stained. All hardware to be galvanized.
All structural metal to be galvanized after fabrication.
Gate mounted on sloping grade shall be oriented to be in closed position when at lower grade point.
Two masonry cells adjacent to each side of gate to be reinforced and grouted.

All wood to be stained. All hardware to be galvanized.
All structural metal to be galvanized after fabrication.
Gate mounted on sloping grade shall be oriented to be in
closed position when at lower grade point.

Two masonry cells adjacent to each side of gate to be reinforced and grouted.



Cut channel to form tapered end. Bend and weld vertical flange as shown.

For location of nylon finishing washers,
see Standard Plan B15-11.



STATE OF CALIFORNIA
DEPARTMENT OF TRANSPORTATION

B15-10